



3) 4-24-04 PROOF TEST.  
 2) HYDRO @ 240 PSIG.  
 NOTE: 1) SHIP LOOSE W/(1) 1 5/16"  $\times$  120" LG. FLEX. MAG. ANODE.

SHELL / HEADS	.245" SA-455 2:1 S.E.	GS-48-900-V	REV. 1-23-07
	JOGGLE - .208 OFFSET		DATE: 6-13-90
SHELL / HEADS	.200" SA-455	FOR: HANSON STANDARD	
		VERT. HOT WATER TANK.	
M.A.W.P.	160 PSIG. @ 210 °F	SURFACE AREA = 136.7 SQ. FT.	
ASME. SECTION	IV 2004 ADD. 2006	INSIDE: GLASS LINED	
X-RAY:	RT-NO / H.L.W.	OUTSIDE: PRIME	
GALLONS:	900	CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		LEG-ZONE 4-15 KM.	
N.B.		BY: J.G.	SCALE: 3/4" = 12"
		<b>ROY E. HANSON JR. MFG.</b>	
		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	